





Newlink CRP Reinforced Brackets

- Sizes: 4", 8" and 12"
- Electro Zinc Resistant Finish
- NEC Approved
- NEWMAX-25 Year Certification available (*)

Technical Specifications:

Steel	(Min. Yield = 33KSI) (35 KSI for Stainless)		
Plain	Hot rolled pickled and oiled steel per ASTM A569 or A570		
Pre-Galvanized	Mill galvanized steel per ASTM A653 CS or SS G90		
Hot Dip Galvanized After	Plain steel which is hot dipped after fabrication per ASTM A123		
Fabrication			
Stainless Steel	Type 304 or 316L fully annealed stainless steel		
NEC Permitted (types of cables)	 Power and Control Tray Cable (Type TC) - NEC Article 336 Power Limited Tray Cable (Type PLTC) - NEC Sections 725-61© and 725.82(E) Instrument Tray Cable (Type ITC) - NEC Article 727 Optical Fiber Cables - Article 770 Fire Alarm Circuit Conductors - Article 760 Communication Cables - Article 800 Mineral Insulated (MI)Cable - Article 332 Metal Clad (MC) Cable - Article 330 		



NEW-8585X00

Ordering Information:

P/N	Description	Set	Finish
NEW-8585100	4" CRP Reinforced Bracket	1	Galvanized
NEW-8585200	8" CRP Reinforced Bracket	1	Galvanized
NEW-8585300	12" CRP Reinforced Bracket	1	Galvanized

^(*) NEWMAX-25 Year Certification applies when a complete Newlink Cabling Channel is installed.